



TÜV NORD CERT

**Certificate about the testing of the
degrees of protection provided by enclosures**

Testing laboratory
Safety of technical systems

Client: Rolec
Gehäuse-Systeme GmbH
Kreuzbreite 2

D – 31737 Rinteln

**Devices under
test:** Enclosure series polyDoor
Series:
PD 120 until PD 202
PD 120 FE until PD 202 FE

**Tested in accordance
to:** EN 60529: 2000 Degrees of protection provided by
enclosures (IP Code)
Requirements towards system of
protection IP 66
Enclosures of category I;
Dust test with negative pressure

Conductor of test: A. Schmidt

Order number: 8000307813

Period of test: from 25.08.2003 until 08.09.2003

Result: The enclosure series polyDoor fulfils the requirements of
the degree of protection IP 66

TÜV NORD CERT GmbH & Co. KG
Am TÜV 1

D – 30519 Hannover

Hannover, 08.09.2003

K. H. Schwedt
Head of testing laboratory
Safety of technical systems